

# Evidence of Performance

## Airborne sound insulation of building elements

### Test report 163 34476/Z5e

This is a translation of the test report 163 34476/Z5 of 15<sup>th</sup> November 2007.



Client **Press Glas S.A.**  
**Nowa Wies**  
Kopalniana 9


42-262 Poczesna  
Poland

#### Basis

EN ISO 140-1:1997+A1:2004  
EN 20140-3 :1995+A1:2004  
EN ISO 717-1 : 1996+A1:2006

Product	Isolation glass unit
Designation	Float 6 mm / 16 / 55.2 Thermofloat Ar.
Size (w × h)	1230 mm × 1480 mm
Construction	6/16/10 LG
Gas filling	Argon
Area related weight	40,4 kg/m <sup>2</sup>
Special items	-/-

#### Representation



#### Informations for use

This test report may be used to validate the sound reduction of a building element.

Validity for germany:

R<sub>w</sub> corresponds to R<sub>w,P</sub> for DIN 4109 Annex 1 table 40

#### Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

#### Notes on publication

The **ift** Guidance Sheet "Conditions and Guidance for the use of **ift** Test Documents" applies.

The cover sheet can be used as a summary.

#### Contents

This test report includes 6 pages

- 1 Test specimen
  - 2 Test procedure
  - 3 Test results
  - 4 Instructions for use
- Data sheet (1 page)

Weighted sound reduction index R<sub>w</sub>  
Spectrum adaptation terms C and C<sub>tr</sub>



$$R_w (C; C_{tr}) = 40 (-1;-4) \text{ dB}$$

ift Rosenheim  
22<sup>nd</sup> November 2007

Dr. Joachim Hessinger, Dipl.-Phys.  
Head of test laboratory  
ift centre for acoustic

Bernd Saß, Dipl.-Ing. (FH)  
vice head of test laboratory  
ift centre for acoustic



LSW - Labor für Schall- und Wärmemesstechnik GmbH  
- das Schallschutzprüfzentrum des ift Rosenheim

Geschäftsführer:  
Dr. Jochen Peichl  
Prof. Fritz Holtz

Lackermannweg 26  
D-83071 Stephanskirchen

Tel. +49 (0)8036/3006-0  
Fax: +49 (0)8036/3006-33  
www.lsw-gmbh.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14822

Sparkasse Rosenheim  
Kto. 500 435 805  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18

Sachverständige Prüfstelle Gruppe I  
für Eignungs- und Güteprüfung DIN 4109