

# Evidence of Performance

## Airborne sound insulation of building elements

### Test report 163 33841/Z3e

This is a translation of the test report 163 33841/Z3 of 20<sup>th</sup> June 2007.



Client **Press Glas S.A.**  
**Nowa Wies**  
Kopalniana 9


42-262 Poczesna  
Poland

#### Foundation

EN ISO 140-1:1997+A1:2004  
EN 20140-3 :1995+A1:2004  
EN ISO 717-1 : 1996+A1:2006

Product	Isolation glass unit
Designation	Float 6 mm / 16 / 55.2 Thermofloat Stratophone Ar.
Size (w × h)	1230 mm × 1480 mm
Construction	6/16/10 LG SI
Gas filling	Argon
Area related weight	40,1 kg/m <sup>2</sup>
Special items	-/-

#### Representation



#### Informations for use

This test report may be used to validate the sound reduction of a building element.

Validity for germany:

R<sub>w</sub> corresponds to R<sub>w,P</sub> for DIN 4109 Annex 1 table 40

Weighted sound reduction index R<sub>w</sub>  
Spectrum adaptation terms C and C<sub>tr</sub>



$$R_w (C; C_{tr}) = 42 (-3;-7) \text{ dB}$$

#### Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

#### Notes on publication

The **ift** notice "Conditions and notes for the use of **ift** test documents" applies.

The cover sheet can be used as a summary.

#### Contents

This test report includes 6 pages

- 1 Test specimen
  - 2 Test procedure
  - 3 Test results
  - 4 Instructions for use
- Data sheet (1 page)

ift Rosenheim  
20. Juni 2007

*J. Hessinger*

Dr. Joachim Hessinger, Dipl.-Phys.  
Head of test laboratory  
ift centre for acoustic

*Bernd Saß*

Bernd Saß, Dipl.-Ing. (FH)  
vice head of test laboratory  
ift centre for acoustic



LSW - Labor für Schall- und Wärmemesstechnik GmbH  
- das Schallschutzprüfzentrum des ift Rosenheim

Geschäftsführer:  
Dr. Jochen Peichl  
Prof. Fritz Holtz

Lackermannweg 26  
D-83071 Stephanskirchen  
Tel.+49 (0) 8036 / 3006-0  
Fax+49 (0) 8036 / 3006-33  
www.lsw-gmbh.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14821  
Sparkasse Rosenheim  
Kto. 500 434 626  
BLZ 711 500 00

Anerkannte Prüf-, Überwachungs- und  
Zertifizierungsstelle nach  
Landesbauordnung: BAY24  
Sachverständige Prüfstelle Gruppe I  
für Eignungs- und Güteprüfung nach DIN 4109