

Inspecta Sertifiointi Oy has granted a product certificate to

Press-Glas SA
Poczesna, Poland
Nova Wies, Ul. Kopalniana 9
42-262 Poczesna
POLAND

to certify that Inspecta Sertifiointi Oy has verified that the following products of the company and their manufacturing quality assurance fulfil the requirements set in the requirement documents **TR 332:2008, EN 1279-1:2005, EN 1279-5:2005, EN 1279-6:2003**

Insulating glass units

Product name: Press-Glas
Type: 2 and 3 panes of glass
Thickness of glass: 3-12 mm
Spacer: aluminium, stainless steel and stainless steel/plastic -composite 9-20 mm
Cavity filling: air or Argon
Argon concentration: 90 % (+10 %, -5 % -units)

Place of manufacture: Tczew, Poland

The company is entitled to use the certification mark on products fulfilling the requirements.
The certificate holder is responsible for ensuring that the products comply with the requirements.

Decision on certification 2011-05-27
(first issue 2005-06-20)

Helsinki 2011-05-27



Anne Qvintus, Managing Director

The certificate is based on initial inspection and type testing. The certificate shall remain valid until further notice provided the requirements set in the General Rules for Product Certification and the above-mentioned product group specific requirement documents are continuously met. The validity of the certificate can be checked at www.inspecta.fi

